

o Structural issues, specifically floor deflections, surfaced between 2009 and 2010. Previous repair attempts had failed to resolve these structural issues. o Specialized engineering firms recommended demolishing the buildings due to significant increases in floor deflections, extensive wall cracks reaching the structural elements, and deteriorating concrete components. o Abu Dhabi Municipality issued numerous notices concerning the deteriorating condition of Al-Taleaa and Al-Janaen schools, citing their negative impact on the public landscape. o Provis Company was tasked with conducting structural assessments to evaluate the schools' condition and provide recommendations following the escalation of floor deflections.