

A theoretical study on a combined power and ejector refrigeration Cycle using zeotropic mixture isobutane/pentane is carried out. The parametric analysis of generator temperature, condenser temperature and evaporator temperature for all the mixtures shows that, all these three thermodynamic parameters have a strong effect on the cycle performance. And mixture isobutane/pentane (50/50) has the maximum exergy efficiency of 7.83%